



Letter No. 670/BPR CIRCLE

Dtd. 04.09.2019.

To

The Principal,  
Kendriya Vidyalaya,  
Hinjilicut, Dist-Ganjam.

Sub :- Issuance of Fire Safety Certificate in respect of Kendriya Vidyalaya,  
Hinjilicut, Dist-Ganjam.

Sir,

With reference to the subject cited above this is to intimate that, you have applied for issuance of Fire Safety Certificate in respect of Kendriya Vidyalaya, Hinjilicut, Dist-Ganjam, presently temporarily functioning in the campus of Brundavan Bidyapitha, Hinjilicut, Dist-Ganjam. In this connection it is to mention that according to Rule-9 (1) (i) of The Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019 the following are required Fire Safety Certificate.

**EDUCATIONAL BUILDINGS**

- ✓ Having a height of twelve meters and above or,
- ✓ Having a built up area of one thousand square meters or above; or
- ✓ Having three storied building;

Hence, the above building/premises having 03 buildings i.e School building=G+1=01 No. of built up area 507.5 M<sup>2</sup>, School building=Ground floor only of floor area 299.3 M<sup>2</sup> & Office building=Ground floor only floor area 146.25 M<sup>2</sup> & total built up area of all floors is 953.05 M<sup>2</sup> do not required Fire Safety Certificate. However, you may install Fire Prevention and Fire Safety measures in your building/premises as per Table-7, Part-IV of National Buiding Code of India-2016.

Yours faithfully,

*D. Swain*  
04.9.19

(Debendra Kumar Swain)  
Deputy Fire Officer,  
Berhampur Circle, Berhampur.